



	VOLTAGE	OP. TIME	PIPE SIZE
G01	125 D.C.	0.5 SEC.	PIVOT, 1" DIA. or 1/4" IPS
G02	120 A.C.	0.5 SEC.	PIVOT, 1" DIA. or 1/4" IPS
G03	240 A.C.	0.5 SEC.	PIVOT, 1" DIA. or 1/4" IPS
G04	125 D.C.	0.8 SEC.	PIVOT, 1" DIA. or 1/4" IPS
G05	120 A.C.	0.8 SEC.	PIVOT, 1" DIA. or 1/4" IPS
G06	240 A.C.	0.8 SEC.	PIVOT, 1" DIA. or 1/4" IPS

G01-G03 - 800@13 1/2" / 1400@7 3/4" LBS THRUST MIN.
 G04-G06 - 1000@13 1/2" / 1600@7 3/4" LBS THRUST MIN.

REVISION
 A. - UPDATED DWG.
 C.L.S. 06/27/00
 B. - FLIP ROD END CLAMP
 RELOCATE HEATER
 MD 07/21/02

NOTE: USE G04-G06 WITH S&C ALDUTI 25/35kV SWITCHES & OFFER OPTIONAL EXTENDABLE PUMP HANDLE.

REV B	Cleaveland/Price, Inc. 1400 Route 993 ; Trafford, PA. 15085		
CODE A CP	DRAWN: JKA	CHECKED: CMC	DATE: 08/28/96
TYPE RP-C2 MOTOR OPERATOR OUTLINE			SCALE: PROPORTIONAL
			DWG NO. C11B002